

DECLARATION OF CONFORMITY



RNG INTERNATIONAL, INC.

RNG INTERNATI

COMPANY : RNG International Inc.

ADDRESS : 5050 S Archibald Ave
Ontario, CA 91762
United States

Declares that the following product:

PRODUCT TYPE : LITHIUM IRON PHOSPHATE BATTERY

BRAND : Renogy

MODEL : RBT12300LFP-M

RATING : DC 12.8V, 300Ah, 3840Wh

Is in conformity with the requirements of the following Directives of the European Union and applicable UK legislation:

1. CE Marking — European Union Directives

EMC Directive 2014/30/EU with the following harmonized standards:

EN IEC 61000-6-3:2021 (Emission standard for residential, commercial and light-industrial environments)

EN IEC 61000-6-1:2019 (Immunity standard for residential, commercial and light-industrial environments)

Restriction of the use of certain Hazardous Substances Directive (RoHS) 2011/65/EU and (EU) 2015/863 with the following harmonized standards:

EN IEC 63000:2018 (Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances)

Test Method References: IEC 62321-3-1:2013, IEC 62321-5:2013, IEC 62321-4:2013+AMD1:2017, IEC 62321-7-1:2015, IEC 62321-7-2:2017, IEC 62321-6:2015, IEC 62321-8:2017

Test Report No.: 182811C400037101 | Issued by: Shenzhen Anbotek Compliance Laboratory Limited | Date: 2024-08-22

CE MARK DATE: August, 2024

2. UKCA Marking — United Kingdom Regulations

Electromagnetic Compatibility Regulations 2016 (UK SI 2016 No. 1091) with the following designated standards:



CS 扫描全能王

3亿人都在用的扫描App

BS EN IEC 61000-6-3:2021

BS EN IEC 61000-6-1:2019

Certificate of Conformity No.: AT182611C4000191 | Report No.: 182611C400019101 |
Issued by: Shenzhen Anbotek Compliance Laboratory Limited | Date: 2024-08-07

3. Transport Safety

UN38.3 (United Nations Manual of Tests and Criteria, ST/SG/AC.10/11/Rev.8, Section 38.3) — Lithium Battery Transportation Safety Testing:

All 8 test items (T.1 Altitude Simulation, T.2 Thermal Test, T.3 Vibration, T.4 Shock, T.5 External Short Circuit, T.6 Impact/Crush, T.7 Overcharge, T.8 Forced Discharge) passed.


Report No.: CESUN250723005 | Issued by: National Engineering Research Center of Advanced Energy Storage Materials Co., Ltd. (CES) | Issue Date: 2025-08-27

Additional Report No.: 182711C400075101 | Issued by: Shenzhen Anbotek Compliance Laboratory Limited | Date: 2024-08-16

The undersigned hereby declares that the equipment specified above conforms to the above Directives and Standards.

Signed

RNG INTERNATIONAL, INC.



Date

2026.5.22

This Declaration of Conformity is issued under the sole responsibility of the manufacturer/importer.

RNG International Inc. | 5050 S Archibald Ave, Ontario, CA 91762, USA

